

SIMPLIFIED SECOND-ORDER GENERALIZED INTEGRATOR – FREQUENCY-LOCKED LOOP

Hafiz AHMED¹, Mohamed BENBOUZID^{2,3}

¹School of Mechanical, Aerospace and Automotive Engineering, Faculty of Engineering, Environment and Computing, Coventry University, Priory Street, CV1 5FB Coventry, United Kingdom

²Department of Electrical Engineering, UMR CNRS 6027 IRDL, University of Brest,
3 Rue des Archives, 29238 Brest, France

³Department of Electrical Engineering, Shanghai Maritime University,
1550 Haigang Ave, 201306 Shanghai, China

hafiz.h.ahmed@ieee.org, mohamed.benbouzid@univ-brest.fr

DOI: 10.15598/aece.v17i4.3540

Abstract. *Second-Order Generalized Integrator – Frequency-Locked Loop (SOGI-FLL) is a popular technique available in the grid synchronization literature. This technique uses gain normalization in the frequency locked-loop. This increases the computational complexity. In this paper, we propose an alternative implementation to reduce the computational complexity of the SOGI-FLL. The proposed implementation modifies mainly the frequency locked-loop part and requires normalized voltage measurement. dSPACE 1104 board-based hardware implementation shows that the proposed implementation executes 20 % faster than the standard implementation. This could be very beneficial for high switching frequency application e.g. ≥ 1 MHz. In addition to the nominal frequency case, multi-resonant implementation is also proposed to tackle grid harmonics using a simpler harmonic decoupling network. Small signal dynamical modeling and tuning are performed for both implementations. Dynamical equivalence is also established between the two implementations. Experimental comparative analysis demonstrates similar or better performance (depending on test scenarios) with respect to the standard implementation of the SOGI-FLL.*

Keywords

Frequency estimation, Frequency Locked-Loop, phase estimation, Second Order Generalized Integrator.

1. Introduction

To reduce the worst impacts of climate change, Renewable Energy Sources (RES) can play a major role. In this regard, International Energy Agency (IEA) set up an ambitious target of 17.6 Gt energy-related carbon emission by 2040 (as opposed to 33.1 Gt in 2018). RES have the potential to contribute in this regard. RES are generally connected through inverters to the traditional power grid. Maximum power can only be transferred to the grid from RES, if the instantaneous phase of both RES and the grid are the same. This process is commonly known as grid synchronization. In addition, many other applications require the phase and frequency information of the traditional power grid [1], [2], [3], [4], [5] and [6]. As phase and frequency information have huge potential implications, this has attracted the attention of wider engineering communities, resulting to an increasing research effort.

In the grid synchronization literature, Phase-Locked Loops (PLL) are widely used. PLL works by synchronizing with the input signal. As such PLLs are sensitive to phase angle jump. To overcome this limitation of PLL, researchers have paid their attention to frequency which very rarely suffers from sudden change in the actual power system. As a result Frequency-Locked Loop (FLL) has been proposed which works by synchronizing itself with the frequency of the input signal.

In the literature of FLL, Quadratic Signal Generators (QSG) are widely used. There are many different QSG techniques available in the literature, e.g. Phase Locked-Loop [7], Enhanced Phased Locked-Loop (EPLL) [8], Second Order Generalized Integrator

(SOGI) [9] and [10] and its various extensions including Double SOGI (DSOGI) [11], self-tuning filter [12], maximum-likelihood estimator [13], state-observer [14] and limit cycle oscillator [15] to name a few. For a constructive review on this topic, please consult [16] and the references therein. Out of various techniques, SOGI based techniques can be considered as one of the most popular one. Popular commercial micro-controllers e.g. C2000™ series from the Texas Instruments has builtin functions for SOGI based technique [17].

Popularity of SOGI based techniques drawn the attention of many researchers. As a result various modifications are proposed in the literature [9]. Modifications were aimed to improve certain performances of SOGI based techniques, e.g. robustness to DC bias, harmonics. However, better performance comes at a cost of additional computational complexity including additional gains to tune. Moreover, as reported in the literature, SOGI-FLL with additional filters have similar convergence speed like SOGI-FLL. Surprisingly, SOGI-FLL has less overshoot that that of SOGI-FLLs with additional filters. As such in this work, we focus on the standard implementation of the SOGI-FLL. Our aim is to reduce the computational complexity of the basic SOGI-FLL while maintaining similar performances.

In many practical applications, high switching frequencies are warranted now a days. High switching frequencies can increase the efficiency and reduce the size of the converter. In [18], the authors have proposed an ultra-fast switching frequency gate driver. Google Little Box challenge also received submissions with MHz fast switching frequency [19]. At the sub-MHz switching frequency range, even a 0.5 μs saving in the computation time can be a game changer. This motivates us to consider the alternative implementation of SOGI-FLL that could be computationally simpler.

In this work, we propose an alternative way to calculate the second state variable of the SOGI-FLL and propose a modification in the FLL equation. This along with the use of normalized or per unit voltage measurement, help to eliminate the need of gain normalization which reduces the computational complexity. Moreover, in the case of harmonics, the proposed approach has a simple harmonic decoupling method. One question that naturally arise is that are the two implementations dynamically equivalent. We address this question through small-signal modeling.

In this paper, an alternative implementation of the standard SOGI-FLL has been proposed. The proposed implementation is computationally simpler and has a simple harmonic decoupling network. Moreover, subject to parameter tuning, SOGI-FLL and the proposed alternative implementation are dynamically equivalent. This alternative implementation is the main contribution of this paper.

The rest of this paper is organized as follows: Sec. 2. describes the proposed approach. Modeling and tuning are studied in Sec. 3. Extension to the case of harmonics is described in Sec. 4. Experimental results are given in Sec. 5. Finally, Sec. 6. concludes this paper.

2. Alternative Implementation of SOGI-FLL




Fig. 1: Block diagram of SOGI-FLL: (a) proposed modification, (b) original with DC bias estimation [20].

Single-phase grid voltage signal with fundamental component and DC bias/offset is given by:

$$\nu(t) = A \sin(\underbrace{\omega t + \varphi}_{\theta}) + A_0, \quad (1)$$

where A is the amplitude, ω is the angular frequency, φ is the phase, A_0 is the DC bias and $\theta \in [0, 2\pi)$ is the instantaneous phase of the grid voltage signal. SOGI-FLL is a popular technique available in the literature to estimate the parameters of the grid-voltage signal (Eq. (1)). SOGI-FLL works through generating the quadrature signal from the grid-voltage signal using SOGI part while FLL part adapts the time-varying grid frequency. In this work, we propose a simple modifications to both SOGI and FLL part. For further reference, we name the proposed modification as Alternative SOGI (ASOGI). The proposed modification is given in Fig. 1(a). The main difference is essentially the absence of gain normalization in the FLL part. As such it can be safely claimed that the complexity is marginally less than the original SOGI-FLL. ASOGI-FLL can be mathematically represented as:

$$\dot{y} = -x\hat{\omega} + \kappa(\nu - y - y_0)\hat{\omega}, \quad (2a)$$

$$\dot{x} = y\hat{\omega}, \quad (2b)$$

$$\dot{z} = -\rho x(\nu - y - y_0)\hat{\omega}, \quad (2c)$$

$$\dot{y}_0 = \mu(\nu - y - y_0), \quad (2d)$$

$$\hat{\theta} = \arctan\left(\frac{y}{-x}\right), \quad (2e)$$

where $\kappa, \rho, \mu > 0$ are tuning parameters, $y(t)$ is the estimated value of $\nu(t)$, $x(t)$ is the estimated quadrature signal of $\nu(t)$, $\hat{\omega}$ is the estimated grid frequency,

$y_0 = \hat{A}_0$ is the estimation of DC bias A_o and $\hat{\theta}$ is the estimated value of θ . An advantage of the proposed modification is that it preserves all the transfer functions of the SOGI-FLL [9]. As such they are avoided here for the purpose of brevity. In the steady-state, solutions of x and y are given as:

$$x = -\hat{A} \cos(\hat{\theta}), \quad (3a)$$

$$y = \hat{A} \sin(\hat{\theta}). \quad (3b)$$

It is to be noted here that amplitude normalization (i.e. measurement in per unit) is necessary for the proposed ASOGI-FLL. Since embedded hardware always work in the low-voltage e.g. 0–5 V (micro-controller), ± 10 V (dSPACE), normalized measurements are a reality in power system control design. As such no additional computational burden is required for the implementation of the proposed technique.

3. Modeling and Tuning

In this section, small signal modeling and tuning of the two different implementations are performed. Small signal modeling will also help to establish the dynamical equivalence between the two implementations.

3.1. Modeling of SOGI-FLL

SOG-FLL shown in Fig. 1(b) can be mathematically described by the following equations:

$$\dot{x} = y, \quad (4a)$$

$$\dot{y} = \alpha(\nu - y - y_0)\hat{\omega} - x\hat{\omega}^2, \quad (4b)$$

$$\dot{\hat{\omega}} = \frac{-\alpha\beta\hat{\omega}^2}{x^2\hat{\omega}^2 + y^2}x(\nu - y - y_0), \quad (4c)$$

$$\dot{y}_0 = \gamma(\nu - y - y_0), \quad (4d)$$

$$\hat{\theta} = \arctan\left(\frac{y}{-x\hat{\omega}}\right), \quad (4e)$$

where $\alpha, \beta, \gamma > 0$ are tuning gains and the rest of the variables retain the same meaning as in Sec. 2. For further analysis, it is assumed that the SOGI-FLL is near the equilibrium state, i.e. $\theta = \hat{\theta}$, $\omega = \hat{\omega}$, $A = \hat{A}$ and $A_0 = \hat{A}_0$.

Using Eq. (1) and Eq. (3), the frequency estimation dynamics can be written as (using similar approaches as presented in [21]):

$$\begin{aligned} \dot{\hat{\omega}} &= \frac{\alpha\beta\hat{\omega}}{\hat{A}^2} \left\{ A \sin(\theta) - \hat{A} \sin(\hat{\theta}) + A_0 - \hat{A}_0 \right\} \hat{A} \cos(\hat{\theta}) = \\ &= \frac{\alpha\beta\hat{\omega}}{2} \left\{ \sin(\theta - \hat{\theta}) + \sin(\theta + \hat{\theta}) - \sin(2\hat{\theta}) \right\} + \\ &\quad + \frac{\alpha\beta\hat{\omega}}{\hat{A}} (A_0 - \hat{A}_0). \end{aligned} \quad (5)$$

Near the equilibrium point or in the quasi-locked state one can safely assume that $A_0 - \hat{A}_0 \rightarrow 0$, $\sin(\theta + \hat{\theta}) - \sin(2\hat{\theta}) \rightarrow 0$ and $\hat{\omega} = \omega_n$. From the small-angle approximation formula, one can write that $\sin(\theta - \hat{\theta}) \approx \theta - \hat{\theta}$. By applying all these simplifications, Eq. (4c) can be written as:

$$\dot{\hat{\omega}} = \frac{\alpha\beta\omega_n}{2}(\theta - \hat{\theta}). \quad (6)$$

To obtain the dynamics of the estimated phase-angle, let us consider the time derivative of Eq. (4e) given as:

$$\begin{aligned} \dot{\hat{\theta}} &= \frac{y^2\hat{\omega} - x\hat{\omega}\dot{y}}{x^2\hat{\omega}^2 + y^2} = \\ &= \frac{-\alpha(\nu - y - y_0)\hat{\omega}^2x + \hat{A}^2\hat{\omega}}{x^2\hat{\omega}^2 + y^2} = \\ &= \hat{\omega} + \frac{-\alpha(\nu - y - y_0)\hat{\omega}^2x}{\hat{A}^2}. \end{aligned} \quad (7)$$

Using Eq. (3) in Eq. (4c), it can be found that:

$$-\alpha(\nu - y - y_0)\hat{\omega}^2x = \dot{\hat{\omega}}\hat{A}^2\beta^{-1}. \quad (8)$$

Using Eq. (8) in Eq. (7), the instantaneous phase angle dynamics can be written as:

$$\dot{\hat{\theta}} = \omega_n + \frac{\dot{\hat{\omega}}}{\beta}. \quad (9)$$

Finally the dynamics of the DC bias estimation can be calculated as:

$$\begin{aligned} \dot{\hat{A}}_0 &= \gamma \left[A_0 + A \sin(\theta) - \hat{A} \sin(\hat{\theta}) - \hat{A}_0 \right] \hat{\omega} = \\ &= \gamma(\theta - \theta_0 + A_0 - \hat{A}_0)\hat{\omega}. \end{aligned} \quad (10)$$

In the quasi-locked state, it can be assumed that $\theta - \hat{\theta} \rightarrow 0$. Then the Eq. (10) can be simplified as:

$$\dot{\hat{A}}_0 = \gamma(A_0 - \hat{A}_0). \quad (11)$$

Based on Eq. (6), Eq. (9) and Eq. (11), the transfer function of the linearized frequency, phase and DC off-set dynamics of SOGI-FLL are given as:

$$\frac{\hat{\omega}(s)}{\omega(s)} = \frac{\frac{\alpha\beta\omega_n}{2}}{s^2 + \frac{\alpha\omega_n}{2}s + \frac{\alpha\beta\omega_n}{2}}, \quad (12a)$$

$$\frac{\hat{\theta}(s)}{\theta(s)} = \frac{\frac{\alpha\omega_n}{2}s + \frac{\alpha\beta\omega_n}{2}}{s^2 + \frac{\alpha\omega_n}{2}s + \frac{\alpha\beta\omega_n}{2}}, \quad (12b)$$

$$\frac{\hat{A}_0(s)}{A_0(s)} = \frac{\gamma\omega_n}{s + \gamma\omega_n}. \quad (12c)$$

3.2. Gain Tuning of SOGI-FLL

To tune the gains of SOGI-FLL, let us consider the standard second-order transfer function denominator polynomial given as:

$$s^2 + 2\zeta\omega'_n s + (\omega'_n)^2 = 0, \quad (13)$$

where ζ and ω'_n are the damping-ratio and natural frequency respectively. We assume that $\omega'_n = \omega_n$. Next, by comparing the Eq. (13) with the denominator polynomials of Eq. (12a) and Eq. (12b), it can be found that:

$$\left. \begin{aligned} \alpha\beta\omega_n &= 2(\omega'_n)^2 \\ \omega'_n &= \frac{\alpha\omega_n}{4\zeta} \end{aligned} \right\} \Rightarrow \beta = \frac{\alpha\omega_n}{8\zeta^2}. \quad (14)$$

Equation (14) can be used to calculate β from α or vice-versa. However, it requires the value of the damping ratio, ζ . Using integral of time weighted absolute error (ITAE) criteria, Subsec. 5.8 in [22] has suggested $\zeta = 1/\sqrt{2}$ as a optimal value for second-order system. This value will be considered here as well. With the selected value of ζ , $\alpha = 1$ corresponds to $\beta = 78.5$. To select the DC loop tuning gain γ , we consider the first-order transfer function Eq. (12c). The settling time of this system is given by:

$$t_{s(DC)} \approx \frac{3.9}{\gamma\omega_n}. \quad (15)$$

A settling time of 50 ms (2.5 cycles) corresponds to $\gamma \approx 0.25$ in Eq. (15). This completes the tuning of the SOGI-FLL.

3.3. Modeling of ASOGI-FLL

Similar to the ideas presented in Subsec. 3.1., linear modeling of the ASOGI-FLL has also been performed. Details are avoided here for the purpose of brevity. The transfer function of the linearized frequency, phase and DC offset dynamics of SOGI-FLL are given as:

$$\frac{\hat{\omega}(s)}{\omega(s)} = \frac{\frac{\rho\omega_n}{2}}{s^2 + \frac{\kappa\omega_n}{2}s + \frac{\rho\omega_n}{2}}, \quad (16a)$$

$$\frac{\hat{\theta}(s)}{\theta(s)} = \frac{\frac{\kappa\omega_n}{2}s + \frac{\rho\omega_n}{2}}{s^2 + \frac{\kappa\omega_n}{2}s + \frac{\rho\omega_n}{2}}, \quad (16b)$$

$$\frac{\hat{A}_0(s)}{A_0(s)} = \frac{\mu}{s + \mu}. \quad (16c)$$

By comparing Eq. (12) and Eq. (16), it can be concluded that SOGI-FLL and ASOGI-FLL are mathematically very similar. Moreover, depending on the parameter values, the two technique coincides e.g. $\kappa = \alpha = 1$, $\mu = \gamma\omega_n$ and $\rho = \beta$. This shows that the two techniques are dynamically equivalent.

3.4. Gain Tuning of ASOGI-FLL

Similar to Subsec. 3.2., by comparing the Eq. (13) with the denominator polynomials of Eq. (16a) and

Eq. (16b), it can be found that

$$\left. \begin{aligned} \rho\omega_n &= 2(\omega'_n)^2 \\ \omega'_n &= \frac{\kappa\omega_n}{4\zeta} \end{aligned} \right\} \Rightarrow \beta = \frac{\kappa^2\omega_n}{8\zeta^2}. \quad (17)$$

Equation (17) can be used to calculate ρ from κ or vice-versa. Similar to Subsec. 3.2., $\zeta = 1/\sqrt{2}$ is selected here as well. With the selected value of ζ , $\kappa = 1$ corresponds to $\rho = 78.5$. To select the DC loop tuning gain μ , we consider the first-order transfer function Eq. (16c). The settling time of this system is given by:

$$t_{s(DC)} \approx \frac{3.9}{\mu}. \quad (18)$$

A settling time of 50 ms (2.5 cycles) corresponds to $\mu \approx 78.5$ in Eq. (15). This completes the tuning of the ASOGI-FLL.

3.5. Remarks on the Similarity between SOGI-FLL and ASOGI-FLL

From the parameter tuning procedures described in Subsec. 3.2. and Subsec. 3.4., it is very clear that ASOGI-FLL and SOGI-FLL have the same linearized dynamics. The main difference is in the signal normalization procedure. SOGI-FLL does feedback linearization type signal normalization while ASOGI-FLL avoids this by using normalized measurement. One criticism of the proposed solution is that the frequency estimation dynamics become dependent on the amplitude changes. However, this is not the case if normalized measurements are used. Normalized or per unit measurements are widely used in the power system estimation literature. It is to be noted here that both techniques are nonlinear. As such having same linear dynamics does not necessarily mean that both techniques would react exactly the same way in the presence of disturbance or harmonics.

4. Multi-Frequency ASOGI-FLL

Harmonics polluted grid voltage signal is given by:

$$v(t) = A_0 + \sum_{i=1,3}^{2n-1} A_i \sin(\underbrace{\omega_i t + \varphi_i}_{\theta_i}), \quad (19)$$

where A_i , ω_i , φ_i and θ_i are the amplitude, angular frequency, phase and instantaneous phase of the individual harmonic components respectively. ASOGI-FLL as described in Sec. 2. considers only the

case of $i = 1$. However, in the presence of harmonics ASOGI-FLL can no longer provide zero steady-state error. To eliminate the steady-state error, following the ideas of [23], parallel operation of the multiple ASOGI block coupled with a frequency identification block can be one possible solution. For further development, we name this structure as parallel ASOGI-FLL (PASOGI-FLL). PASOGI-FLL can be mathematically represented as for n number of frequency components with $i = 1, 2, \dots, n$ as:

$$\dot{y}_i = -x_i \omega_i + \alpha e \omega_i, \tag{20a}$$

$$\dot{x}_i = y_i \omega_i, \tag{20b}$$

$$\dot{z} = -\beta x_1 e \omega, \tag{20c}$$

$$\dot{y}_0 = \gamma e, \tag{20d}$$

with $\omega_i = \omega \cdot i$ and $e = (v - y_0 - y_1 - y_2 - \dots - y_n)$. Graphical representation of PASOGI-FLL is given in Fig. 2. This figure shows that PASOGI-FLL has a very simple harmonic decoupling network. This can be considered an improvement w.r.t. the harmonic decoupling network of the standard SOGI-FLL given in Fig. 8 of [20].

For the sake of computational simplicity, let us consider that only the third harmonics is present. In this case, the grid frequency estimation transfer function is given by:

$$\frac{y(s)}{v(s)} = \frac{s\alpha(\omega_1 + \omega_3)(s^2 + \omega_1\omega_3)}{s^4 + a_3s^3 + a_2s^2 + a_1s + a_0}, \tag{21}$$

where $a_3 = \alpha(\omega_1 + \omega_3)$, $a_2 = (\omega_1^2 + \omega_3^2)$ and $a_1 = \alpha\omega_1\omega_2(\omega_1 + \omega_2)$ and $a_0 = \omega_1^2\omega_2^2$. Bode magnitude plot of the transfer function is given in Fig. 3. Figure 3 demonstrates excellent filtering property of PASOGI.




Fig. 2: Block Diagram of the PASOGI-FLL.




Fig. 3: Bode magnitude plot of the PASOGI.

5. Experimental Results

To evaluate the performance of the two techniques, dSPACE®1104 board based Hardware-In-the-Loop (HIL) experimental study has been performed. Voltage signal was acquired using the built-in 12-bit LTC1410 Analog-to-Digital Converter (ADC) from Analog Devices. The two techniques have been implemented in Matlab/Simulink with a sampling frequency of 10 kHz. All the continuous integrators are implemented using third-order discrete integrator [23]. The same parameter values are selected as given in Subsec. 3.2. and Subsec. 3.4. Block diagram representation of the experimental setup is given in Fig. 4.




Fig. 4: Block diagram of the experimental setup.

To test the computational efficiency, dSPACE Profile has been used. According to the Profiler, the average execution time for ASOGI-FLL is approximately 2.35 μ s while SOGI-FLL took approximately 2.95 μ s. This counts for roughly 20 % time saving by the proposed implementation. It is to be noted here that dSPACE 1104 board is a powerful embedded computing hardware. For low-cost domestic applications, lower end micro controllers are more widely used. There is a possibility that the execution time saving could be even higher in those low-cost micro-controllers. However, this is yet to be tested.

To test the algorithms, we have considered grid voltage signal with and without harmonics. For the harmonics case, we considered the grid voltage has 20 % Total Harmonic Distortion (THD) comprising of third, fifth and seventh order harmonics. In both cases, sudden jump of frequency, phase, amplitude and DC offset are considered. Comparative experimental results and test conditions are given in Fig. 5 and Fig. 6.

Frequency jump test: Both techniques have similar performances in terms of frequency estimation. How-




Fig. 5: Comparative experimental results: harmonics free case.




Fig. 6: Comparative experimental results with multiple parallel filters: grid voltage contains 20 % THD.

ever, the techniques slightly differed in terms of phase estimation error. ASOGI’s peak frequency estimation error is slightly higher than that of SOGI. Same goes for the case with harmonics.

Phase jump test: Similar behavior can be seen as that of frequency jump tests i.e. frequency estimation performance is very similar and slight difference for the phase estimation error. It is to be mentioned here that in the presence of harmonics, ASOGI converged faster than SOGI.

Amplitude jump test: In this case, significant performance difference can be observed between SOGI and ASOGI. With and without harmonics, both frequency and phase estimation error for ASOGI converged much faster than SOGI. In addition, the peak overshoot and peak estimation error were slightly smaller for ASOGI than that of SOGI.

DC jump test: This test demonstrate that ASOGI has much faster and smoother dynamics compared to SOGI. The frequency and phase estimation error converged at least 1 full cycle faster w.r.t. SOGI. Decaying oscillatory transient response can be seen for SOGI while no such phenomenon can be observed for ASOGI.

In addition to the above attractive features, in the case of multiple adaptive filters, the harmonic decoupling network is very simple for ASOGI-FLL where as SOGI-FLL has a complicated harmonic decoupling

network structure. SOGI-FLL uses FLL gain normalization where as ASOGI-FLL does not use any gain normalization. Despite these differences, the performances of both techniques are similar. These results demonstrate the effectiveness of the proposed alternative implementation of the SOGI-FLL.

6. Conclusions

In this paper, an alternative implementation of the SOGI-FLL has been proposed for both nominal and distorted grid conditions. In the case of distorted grid, the proposed approach uses multiple filters in parallel using a simple harmonic decoupling network. The proposed modifications eliminate the need of FLL gain normalization. In this regard, it reduces the computational complexity. Extensive experimental results are presented. Experimental results demonstrated the suitability of the proposed alternative implementation. The proposed approach performed similar to SOGI-FLL when the grid voltage suffered from sudden jump in phase and frequency while performed better when the grid voltage suffered sudden jump in amplitude and DC offset.

References

- [1] LEKOUAGHET, B., A. BOUKABOU, N. LOURCI and K. BEDRINE. Control of PV grid connected systems using MPC technique and different inverter configuration models. *Electric Power Systems Research*. 2018, vol. 154, iss. 1, pp. 287–298. ISSN 0378-7796. DOI: 10.1016/j.epsr.2017.08.027.
- [2] SAFA, A., E. L. M. BERKOUK, Y. MESSLEM, Z. CHEDJARA and A. GOUICHICHE. A Pseudo Open Loop Synchronization technique for heavily distorted grid voltage. *Electric Power Systems Research*. 2018, vol. 158, iss. 1, pp. 136–146. ISSN 0378-7796. DOI: 10.1016/j.epsr.2018.01.014.
- [3] ABOUDRAR, I., S. EL HANI, H. MADIOUNI and A. AGHMADI. Modeling and Robust Control of a Grid Connected Direct Driven PMSG Wind Turbine By ADRC. *Advances in Electrical and Electronic Engineering*. 2018, vol. 16, iss. 4, pp. 402–413. ISSN 1336-1376. DOI: 10.15598/aeec.v16i4.2952.
- [4] SAFA, A., E. M. BERKOUK, Y. MESSLEM and A. GOUICHICHE. A robust control algorithm for a multifunctional grid tied inverter to enhance the power quality of a microgrid under unbalanced conditions. *International Journal of Electrical Power & Energy Systems*. 2018, vol. 100, iss. 1, pp. 253–264. ISSN 0142-0615. DOI: 10.1016/j.ijepes.2018.02.042.
- [5] MERAL, M. E. and D. CELIK. A comprehensive survey on control strategies of distributed generation power systems under normal and abnormal conditions. *Annual Reviews in Control*. 2019, vol. 47, iss. 1, pp. 112–132. ISSN 1367-5788. DOI: 10.1016/j.arcontrol.2018.11.003.
- [6] AHMED, H., M. BIERHOFF and M. BENBOUZID. Multiple Nonlinear Harmonic Oscillator-Based Frequency Estimation for Distorted Grid Voltage. *IEEE Transactions on Instrumentation and Measurement*. 2019, pp. 1–9. ISSN 0018-9456. DOI: 10.1109/TIM.2019.2931065.
- [7] MERAL, M. E. and D. CELIK. Benchmarking simulation and theory of various PLLs produce orthogonal signals under abnormal electric grid conditions. *Electrical Engineering*. 2018, vol. 100, iss. 3, pp. 1805–1817. ISSN 0948-7921. DOI: 10.1007/s00202-017-0660-x.
- [8] KARIMI-GHARTEMANI, M. *Enhanced Phase-Locked Loop Structures for Power and Energy Applications*. 1st ed. Hoboken: John Wiley & Sons, 2014. ISBN 1-118-79502-6.
- [9] KHERBACHI, A., A. CHOUDER, A. BENDIB, K. KARA and S. BARKAT. Enhanced structure of second-order generalized integrator frequency-locked loop suitable for DC-offset rejection in single-phase systems. *Electric Power Systems Research*. 2019, vol. 170, iss. 1, pp. 348–357. ISSN 0378-7796. DOI: 10.1016/j.epsr.2019.01.029.
- [10] AHMED, H., M. L. PAY, M. BENBOUZID, Y. AMIRAT and E. ELBOUCHIKHI. Hybrid Estimator-Based Harmonic Robust Grid Synchronization Technique. *Electric Power Systems Research*. 2019, vol. 177, iss. 1. ISSN 0378-7796. DOI: 10.1016/j.epsr.2019.106013.
- [11] MERAL, M. E. and D. CELIK. DSOGI-PLL Based Power Control Method to Mitigate Control Errors Under Disturbances of Grid Connected Hybrid Renewable Power Systems. *Advances in Electrical and Electronic Engineering*. 2018, vol. 16, iss. 1, pp. 81–91. ISSN 1336-1376. DOI: 10.15598/aeec.v16i1.2485.
- [12] BOUSSAID, A., A. L. NEMMOUR, L. LOUZE and A. KHEZZAR. A novel strategy for shunt active filter control. *Electric Power Systems Research*. 2015, vol. 123, iss. 1, pp. 154–163. ISSN 0378-7796. DOI: 10.1016/j.epsr.2015.02.008.
- [13] CHOQUEUSE, V., A. BELOUCHRANI, E. H. ELBOUCHIKHI and M. BENBOUZID. Estimation of Amplitude, Phase and Unbalance Parameters in Three-phase Systems: Analytical Solutions, Efficient Implementation and Performance Analysis. *IEEE Transactions on Signal Processing*. 2014, vol. 62, iss. 16, pp. 4064–4076. ISSN 1053-587X. DOI: 10.1109/TSP.2014.2333565.
- [14] AHMED, H., S.-A. AMAMRA and I. SALGADO. Fast Estimation of Phase and Frequency for Single Phase Grid Signal. *IEEE Transactions on Industrial Electronics*. 2019, vol. 66, iss. 8, pp. 6408–6411. ISSN 0278-0046. DOI: 10.1109/TIE.2018.2860567.
- [15] AHMED, H., S.-A. AMAMRA and M. BIERHOFF. Frequency-Locked Loop-Based Estimation of Single-Phase Grid Voltage Parameters. *IEEE Transactions on Industrial Electronics*. 2019, vol. 66, iss. 11, pp. 8856–8859. ISSN 0278-0046. DOI: 10.1109/TIE.2018.2873527.
- [16] JAALAM, N., N. A. RAHIM, A. H. A. BAKAR, C. TAN and A. M. A. HAIDAR. A comprehensive review of synchronization methods for grid-connected converters of renewable energy source. *Renewable and Sustainable Energy Reviews*. 2016, vol. 59, iss. 1, pp. 1471–1481. ISSN 1364-0321. DOI: 10.1016/j.rser.2016.01.066.

- [17] BHARDWAJ, M. Software phased-locked loop design using C2000TM microcontrollers for single phase grid connected inverter. In: *Texas Instruments: Application Report* [online]. 2013. Available at: <http://www.ti.com/lit/an/sprabt3a/sprabt3a.pdf>.
- [18] DYMOND, H. C. P., J. WANG, D. LIU, J. J. O. DALTON, N. MCNEILL, D. PAMUNUWA, S. J. HOLLIS and B. H. STARK. A 6.7-GHz Active Gate Driver for GaN FETs to Combat Overshoot, Ringing, and EMI. *IEEE Transactions on Power Electronics*. 2018, vol. 33, iss. 1, pp. 581–594. ISSN 0885-8993. DOI: 10.1109/TPEL.2017.2669879.
- [19] BORTIS, D., D. NEUMAYR and J. W. KOLLAR. η p-Pareto Optimization and Comparative Evaluation of Inverter Concepts considered for the GOOGLE Little Box Challenge. In: *17th Workshop on Control and Modeling for Power Electronics*. Trondheim: IEEE, 2016, pp. 1–11. ISBN 978-1-5090-1815-4. DOI: 10.1109/COMPEL.2016.7556767.
- [20] RODRIGUEZ, P., A. LUNA, I. CANDELA, R. MUJAL, R. TEODORESCU and F. BLAAB-JERG. Multiresonant Frequency-Locked Loop for Grid Synchronization of Power Converters Under Distorted Grid Conditions. *IEEE Transactions on Industrial Electronics*. 2011, vol. 58, iss. 1, pp. 127–138. ISSN 0278-0046. DOI: 10.1109/TIE.2010.2042420.
- [21] PAY, M. L. and H. AHMED. Modeling and Tuning of Circular Limit Cycle Oscillator FLL With Pre-Loop Filter. *IEEE Transactions on Industrial Electronics*. 2019, vol. 66, iss. 12, pp. 9632–9635. ISSN 0278-0046. DOI: 10.1109/TIE.2019.2892677.
- [22] SHINNERS, S. M. *Modern Control System Theory and Design*. 2nd ed. New York: John Wiley & Sons, 1998. ISBN 0-471-24906-1.
- [23] TEODORESCU, R., M. LISERRE and P. RODRIGUEZ. *Grid Converters for Photovoltaic and Wind Power Systems*. 1st ed. Hoboken: John Wiley & Sons, 2011. ISBN 0-470-05751-3.
- Engineering from Ahsanullah University of Science and Technology, Dhaka, Bangladesh, in 2011, the M.Sc. degree in Systems, Control and Information Technology from Joseph Fourier University, Grenoble, France, in 2013, and the Ph.D. degree in Automatic Control from the University of Lille 1, France, in 2016. For the Ph.D. thesis, he received the EECI (European Embedded Control Institute) Ph.D. award, 2017. He has also obtained the Best Ph.D. Theses award from the Research Cluster on Modeling, Analysis and Management of Dynamic Systems (GDR-MACS) of the National Council of Scientific Research (CNRS) in France in 2017. He was a Postdoctoral fellow at Clemson University, SC, USA followed by academic appointments in Bangladesh at the University of Asia Pacific and North South University. Since September 2017, he joined the School of Mechanical, Aerospace and Automotive Engineering, Coventry University, United Kingdom. He is interested in applied control engineering with special focus in energy and environment. He is an Associate Editor of the International Journal of Electrical Engineering & Education.

Mohamed BENBOUZID received the B.Sc. degree in electrical engineering from the University of Batna, Batna, Algeria, in 1990, the M.Sc. and Ph.D. degrees in electrical and computer engineering from the National Polytechnic Institute of Grenoble, Grenoble, France, in 1991 and 1994, respectively, and the Habilitation r Diriger des Recherches degree from the University of Picardie "Jules Verne", Amiens, France, in 2000. After receiving the Ph.D. degree, he joined the Professional Institute of Amiens, University of Picardie "Jules Verne", where he was an Associate Professor of electrical and computer engineering. Since September 2004, he has been with the University of Brest, Brest, France, where he is a Full Professor of electrical engineering. Prof. Benbouzid is also a Distinguished Professor and a 1000 Talent Expert at the Shanghai Maritime University, Shanghai, China. His main research interests and experience include analysis, design, and control of electric machines, variable-speed drives for traction, propulsion, and renewable energy applications, and fault diagnosis of electric machines. Prof. Benbouzid is a Fellow of the IET and an IEEE Senior Member. He is the Editor-in-Chief of the International Journal on Energy Conversion. He is also an Associate Editor of the IEEE Transactions on Energy Conversion and the IEEE Transactions on Vehicular Technology. He is a Subject Editor for the IET Renewable Power Generation.

About Authors

Hafiz AHMED was born in Dhaka, Bangladesh. He received the B.Sc. degree in Electrical & Electronic